

ADDENDUM NO. 1

January 16, 2018

REQUEST FOR PROPOSAL

City of Menominee

WASTE WATER TREATMENT PLANT

GRIT ROOM DUCT WORK REPLACEMENT

This ADDENDUM NO. 1, issued January 16, 2018, is to add to the scope of work in the “Services To Be Performed” section of the original Request for Proposal document issued by the City of Menominee.

You are required to acknowledge receipt of this ADDENDUM NO. 1 on the bid form or by separate memorandum.

This addendum includes the following item:

1. Addition to 1.3 “Services To Be Performed”

1.3.3 Remove and dispose of existing exhaust fan, louvers and surrounding duct work. Furnish and install exhaust fan and motor, backdraft damper and necessary duct work. Exhaust fan and motor shall be explosion proof, 208 volt and single phase. It shall be capable of producing at least 2,750 CFM. Any electrical upgrades will be the responsibility of the City. An access door shall be installed in the duct work for accessing the damper.

END OF ADDENDUM NO. 1